



Industrie Service

Herewith is granted the right to the company

Rosenberg Ventilatoren GmbH

in

D-74653 Künzelsau - Gaisbach

for the operated fan test rig

„Mittlerer Prüfstand“

located in

D-74653 Künzelsau – Gaisbach

for the volumetric flow range of 100 m³/h to 11,000 m³/h and a pressure range up to 2000 Pa,

based on the positive results of the completed Tests regarding compliance with the requirements of the Standard
DIN EN ISO 5801:2011-11

to identify this with the following
TÜV SÜD Certification Mark.



This certificate is valid until 2016-12-31

Certificate Registration Number: 08/11/002-DE-Rev.2

Certification Body for Products
Refrigeration and Air-Conditioning
Munich, 2015-12-08



