

CERTIFICATE OF COMPLIANCE

Certificate Number 20150203-R21930
Report Reference R21930-20141128
Issue Date 2015-FEBRUARY-03

Issued to: BETA INDUSTRIAL L L C
ALQOUZ
P.O.BOX 50708
DUBAI UNITED ARAB EMIRATES

**This is to certify that
representative samples of**

DAMPERS FOR FIRE BARRIER AND SMOKE
APPLICATIONS

Combination Fire and Smoke Dampers Models:

3 Hr Fire endurance rating, Leakage Class II,
Model BMFSD/T, BMFSD/R-T

1.5 Hr Fire endurance rating, Leakage Class II,
Model BEMFSD-T, BEMFSD/R-T

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 555, Fire Dampers
UL 555S, Smoke Dampers

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

